

### SUPPLEMENTAL BID BULLETIN NO. 1

#### DESIGN AND BUILD OF THE ESTABLISHMENT OF NFA MODERNIZED WAREHOUSES IN SUPPORT TO BUFFER STOCKING PROGRAM AT VARIOUS NFA COMPOUNDS IN REGION I (2ND RE-BIDDING)

(Project Identification No. 2025-14)

22 JULY 2025

The NFA Central Office Bids and Awards Committee (BAC) issues this Bid Bulletin to correct/ amend and clarify certain items in the Bid Documents relative to the bidding for the Design and Build of the Establishment of NFA Modernized Warehouses in Support to Buffer Stocking Program at Various NFA Compounds in Region I, as follows:

#### I. AMENDMENTS

REFERENCE	REVISION/AMENDMENT	
	FROM	TO
Section VI. Specifications (Terms of Reference)  Part IX – Technical Specifications	1.14 Concrete slab on-fill must be able to carry moving loads from trucks;	1.14 The concrete slab on fill shall be designed to support moving truck loads, with a minimum slab thickness of 0.30 meters.

All other provisions/instructions in the bid documents not mentioned in this Bid Bulletin shall remain in full force and effect without any modification.

Likewise, all items in the Bidding Documents not consistent with the above corrections shall be deemed changed and amended accordingly.



**ENGR. JOHN ROBERT R. HERMANO**  
*Chairperson, Bids and Awards Committee*